

Data Sheet

Use of propane gas

1. Contact person

Leipziger Messe GmbH
Technical Event Management Department (TI-VT)

Messe Allee 1
04356 Leipzig

Tel.: 0341 / 678 - 9906
E-Mail: veranstaltungstechnik@leipziger-messe.de

This department coordinates all required boundary conditions with the company's project manager.

2. Application area and principles

This data sheet applies solely to the premises of Leipziger Messe GmbH. Liquid gas may only be used with the express approval of Leipziger Messe. Approval must be obtained in writing (order form A12 "Pressurised and liquid gas cylinders" or online ordering system). The provisions are enshrined in the Technical Guidelines (5.7.1).

3. Requirements and information

The gas is required for the presentation of an exhibit.

The installation location must be coordinated with Technical Event Management. It must be marked with a warning sign (W19).

The gas may only be connected following a gas safety inspection (subject to charges). (Inspection of supply line and pressure regulating equipment). Request on-site testing via any telephone at all hall gates on speed dial 9906

Suitable extinguishing materials must be made available (at least one powder fire extinguisher min. 6 LE).

Gas bottles may only be replaced outside of event hours. Replacements are provided either by the specialist firm of Leipziger Messe, or the specialist firm of Leipziger Messe must inspect the compressed gas system after the bottles have been replaced.

4. Implementation

Use may only be commenced once all boundary conditions and requirements have been met.